



TeSuCon

Technical Support & Consultancy

REPORT TURBINE INSPECTION
SN 15401268, WINDPARK SLUFTER WEST 2



Report No. GE15002015002

18-11-2015

CONFIDENTIAL – Distribution to 3rd parties strictly prohibited

Contents

1 Purpose 3

2 Abbreviations..... 3

3 General information 4

4 Wind turbine main components 4

5 Documents..... 5

6 Logbook: Overview of recent maintenance 6

7 Logbook: Notable events 6

8 Tower and towerbase 7

9 Yaw system 8

10 Nacelle 9

11 Hydraulic system and brake 10


12 Gearbox and main shaft 10


13 Generator and coupling 12

14 Hub..... 13

15 Rotor blades 17

16 Conclusion..... 18



 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 2 of 18	

1 Purpose


On behalf of Vattenfall an inspection has been executed on the wind turbine. The purpose of the inspection is to determine the technical state of the wind turbine.

2 Abbreviations

ok	okay
nok	not okay
na	not applicable
nav	not available
nc	not checked
info	for information purpose

Items marked with "ok" and "info" show no visual irregularities. All issues which are not acceptable are marked with "nok". Items which are "nok" will be classified in three different classes.

Class	Clarification	Description in report
Priority Low	An irregularity, which is not a safety issue, and is relatively easy to solve.	<i>Low</i>
Priority High	An irregularity, which is not a safety issue, and is more serious and is more time and/or money consuming to solve.	<i>High</i>
Safety Issue	Issues which concern the safety of the people working in the turbine.	<i>Safe</i>


 TeSuCon Technical Support & Consultancy	Wind turbine inspection Windpark Slufter West 2	15401268
	Date: 18-11-2015	Page 3 of 18

3 General information

Wind turbine name:	Windpark Slufter West 2
Wind turbine type:	GE1.5S
Wind turbine S/N:	15401268
Location:	Rotterdam-Maasvlakte, NL
Hub height:	65
Nominal power [kW]:	1500
Year of installation:	2003
Date of inspection:	14-10-2015
Inspectors:	D. Lagerweij J. Langenbach


4 Wind turbine main components

Component	Type	Year	Serial number
Convertor	GE Power Convertor 151X1228KA025A01	-	DS008VIA
Gearbox	Lohmann + Stolterfoht GPV 451	2003	1044369
Revision gearbox	-	-	-
Gearbox oil	Castrol Optigear Syn A320 <i>(according to label in towerbase)</i>	2012	-
Generator	VEM DASAA 5023-4UF	2003	2345001
Blade 1	GE Rotor Blades	-	2398
Blade 2	GE Rotor Blades	-	2297
Blade 3	GE Rotor Blades	-	2404

 TeSuCon <small>Technical Support & Consultancy</small>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 4 of 18	

5 Documents

	Component	Remark	
1	Operator manual	<p>Operating manual is available at the turbine.</p> <p>Machine directive 2006/45/EC, 1.7.4.2 states as part of the Contents of instructions:</p> <p><i>"(e) the drawings, diagrams, descriptions and explanations necessary for the use, maintenance and repair of the machinery and for checking its correct functioning;"</i></p>	ok
2	Wiring diagram	<p>Wiring diagrams are not available at the turbine.</p> <p>Machine directive 2006/45/EC, 1.7.4.2 states as part of the Contents of instructions:</p> <p><i>"(e) the drawings, diagrams, descriptions and explanations necessary for the use, maintenance and repair of the machinery and for checking its correct functioning;"</i></p>	ok
3	Hydraulic diagram	<p>Hydraulic diagrams are not available at the turbine.</p> <p>Machine directive 2006/45/EC, 1.7.4.2 states as part of the Contents of instructions:</p> <p><i>"(e) the drawings, diagrams, descriptions and explanations necessary for the use, maintenance and repair of the machinery and for checking its correct functioning;"</i></p>	nok
4	Maintenance manual	<p>Maintenance manual is not available at the turbine.</p> <p>Machine directive 2006/45/EC, 1.7.4.2 states as part of the Contents of instructions:</p> <p><i>"(e) the drawings, diagrams, descriptions and explanations necessary for the use, maintenance and repair of the machinery and for checking its correct functioning;"</i></p>	nok
5	Logbook	Logbook is available at the turbine.	ok


 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 5 of 18	

6 Logbook: Overview of recent maintenance





Year	Type of maintenance	Date of execution	Maintenance schedule
	Commissioning	09-2003	2003
...
9	1 year service	26-11-2012	2012
9½	½ year service	20-03-2013	
10	1 year service	05-09-2013	2013
10½	½ year service	02-04-2014	
11	1 year service	17-11-2014	2014
11½	½ year service	07-05-2015	
12	1 year service	<i>no service record</i>	2015


7 Logbook: Notable events

Date	Event
...	...
13-12-2010	Gear oil pump exchange
29-06-2012	Exchange HSS bearings
08-05-2015	6 battery packs exchanged blade 1,2 and 3

 TeSuCon <small>Technical Support & Consultancy</small>	Wind turbine inspection Windpark Slufter West 2	15401268
	Date: 18-11-2015	Page 6 of 18


8 Tower and towerbase

Item	Remark		
1	Tower outside Light at the outside is broken and has damaged the paint of the tower. Caps from a few bolts of the bottom flange are missing.		<div style="text-align: right;">  Low </div>
2	Controller overview		<div style="text-align: right;"> Info </div>
3	Tower inside		<div style="text-align: right;"> Info </div>
4	Miscellaneous		<div style="text-align: right;"> ok </div>

 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 7 of 18	


9 Yaw system

	Item	Remark	
1	Yaw section		ok
2	Yaw ring teeth	<p>Yaw ring shows no irregularities.</p> 	ok
3	Yaw pinions	<p>Yaw pinions show no irregularities.</p> 	ok
4	Yaw gears	<p>Several bolts between the gear and the frame are corroded (1st picture). Several air outlets of the oil reservoirs are corroded.</p> 	<p>not Low</p>

 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 8 of 18	

10 Nacelle



	Item	Remark	
1	Nacelle overview		Info
2	Frame	Turbine is equipped with a cast-iron frame. 	Info
3	Nacelle housing	Parts of the insulation are damaged. 	<div style="text-align: center;">  Low </div>
4	Weather station		ok
5	Controller overview		Info


 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 9 of 18	

11 Hydraulic system and brake

	Item	Remark	
1	Overview		Info
2	Leakage		ok
3	Miscellaneous		ok


12 Gearbox and main shaft

	Item	Remark	
1	Main shaft bearings	Grease of the main bearing is not magnetic. 	ok
2	Radiators	Leakage at the radiator. 	<div style="color: red; font-weight: bold;">nok</div> High
3	CCJ-unit	No CCJ-filter present in the turbine.	Info

 TeSuCon Technical Support & Consultancy	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 10 of 18	


4	Gear oil system	Leakage visible at the filter unit and on the frame under the unit. 	<div style="text-align: center;">  <i>High</i> </div>
5	Hoses and pipes		ok
6	Paint / Corrosion		ok
7	General leakage		ok
8	Slip ring for hub		<div style="text-align: center;"> <i>Info</i> </div>



 TeSuCon <small>Technical Support & Consultancy</small>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 11 of 18	


13 Generator and coupling




Item	Remark		
1	Coupling	<p>The coupling shows no irregularities.</p> 	Info
2	Paint / Corrosion		ok
3	Slip ring	<p>Raceway of the earth connection is not completely smooth (3th picture). The insulating parts between the phases are covered with black carbon dust (arrows in 4th picture).</p> 	<p>nok High</p>


 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 12 of 18	

14 Hub


	Item	Remark	
1	Blade bearing	<p>Small cracks visible at the caps of the blade bearing bolts (2nd picture).</p> 	<p>Info Low</p>
2	Overview inside	<p>In general, the hub is clean and there is no excessive corrosion present.</p> 	<p>Info</p>
3	Hub cabinet overview		<p>Info</p>
4	Boxes blade 1	<p>Control box and battery box show no irregularities.</p> 	<p>ok</p>

 <p>TeSuCon Technical Support & Consultancy</p>	<p>Wind turbine inspection Windpark Slufter West 2</p>		<p>15401268</p>
	<p>Date: 18-11-2015</p>	<p>Page 13 of 18</p>	

5	Boxes blade 2	<p>Control box and battery box show no irregularities.</p> 	ok
6	Boxes blade 3	<p>Control box and battery box show no irregularities.</p> 	ok
7	Mounting of the electrical boxes	<p>The mounting of the boxes shows no irregularities.</p> 	ok

 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 14 of 18	


8	Pinions of pitch gears	<p>Wear on one tooth of the pinions of the pitch gears.</p> 	<p>NOK High</p>
9	Pitch teeth at zero of blade 1	<p>The tooth at zero shows wear.</p> 	<p>NOK High</p>
10	Pitch teeth at zero of blade 2	<p>The tooth at zero shows wear.</p> 	<p>NOK High</p>

 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 15 of 18	

11	Pitch teeth at zero of blade 3	The tooth at zero shows wear.		<div style="text-align: center;">  High </div>
12	Grease system pitch teeth	There is an automatic grease system present in the hub. The system is not operational.		<div style="text-align: center;">  High </div>
13	Pitch gears		<div style="text-align: center;">ok</div>	
14	Miscellaneous		<div style="text-align: center;">ok</div>	

15 Rotor blades

1	Blades	<p>Repaired parts are visible on the leading edges of the blades.</p> 	Info
---	--------	---	------

 <p>TeSuCon Technical Support & Consultancy</p>	Wind turbine inspection Windpark Slufter West 2		15401268
	Date: 18-11-2015	Page 17 of 18	

16 Conclusion

The logbook shows that the turbine has been maintained on a regular basis, according to the maintenance schedule of GE.

The original gearbox is present in the turbine and the high speed shaft bearings of the gearbox have been replaced in 2012. The original generator is also present in the turbine.

The blades have been maintained recently.

The wear of the zero-tooth of the pitch ring is serious, but it is possible to solve this problem by assigning another tooth to be the zero-tooth. Dismounting and remounting of the blades is necessary to achieve this. The same thing can be done with the pinions, although replacing the pitch gears (with the pinions) is also an option.


The overall condition of the turbine is quite acceptable for a twelve year old turbine. There are however several issues (marked as **red** in this report) present and it is recommended to solve these, in order to improve the condition of the turbine.



D. Lagerweij

18-11-2015

TeSuCon B.V.
Mercuriusweg 8
3771NC Barneveld
+31610032858
dl@tesucon.nl
www.tesucon.nl


 TeSuCon Technical Support & Consultancy	Wind turbine inspection Windpark Slufter West 2	15401268
	Date: 18-11-2015	Page 18 of 18



TeSuCon

Technical Support & Consultancy

REPORT GEARBOX INSPECTION
SN 15401268, WINDPARK SLUFTER WEST 2



Report no. GE15002015012

24-11-2015

CONFIDENTIAL – Distribution to 3rd parties strictly prohibited

Contents

1. Purpose 3

2. General Information 3


3. Reporting setup 4

4. Inspection results 5

5. Summary 17

6. Conclusion 17



 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 2 of 17	


1. Purpose

On behalf of Vattenfall an inspection has been executed on the wind turbine gearbox. The purpose of the inspection is to determine the technical state of the gearbox. The visual inspection of the gearbox has been executed with a GE Everest XLG3 Videoscoop.

2. General Information


Turbine Information	
Wind turbine name:	Windpark Slufter West 2
Wind turbine type:	GE1.5S
Wind turbine serial no:	15401268
Location:	Rotterdam-Maasvlakte, NL
Hub height:	65
Nominal power [kW]:	1500
Year of installation:	2003
Date of inspection:	14-10-2015
Inspectors:	D. Lagerweij J. Langenbach

Gearbox Information	
Gearbox type:	Lohmann + Stolterfoht GPV 451 <i>i = 88,81</i>
Gearbox serial number:	1044369
Production year gearbox:	2003
Revision:	-
Revision number:	-
Oil type:	Castrol Optigear Syn A320 <i>(according to label in towerbase)</i>
Date of last oil change:	29-06-2012

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 3 of 17	


3. Reporting setup

The next drawing shows a cross-section of a planetary gearbox with two linear stages with corresponding bearing positions. The drawing should be used as a reference for the bearing position only.




 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015		Page 4 of 17

4. Inspection results




Picture 1


Picture 1 shows bearing position no. 1, the bearing of the planet carrier at rotor side. No irregularities.



Picture 2


Picture 2 shows the bearing of the first planet wheel. Surface of the inner guide ring is roughened.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 5 of 17	



Picture 3


Picture 3 shows the bearing of the second planet wheel. No irregularities.



Picture 4


Picture 4 shows the bearing of the third planet wheel. No irregularities.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 6 of 17	



Picture 5


Picture 5 shows bearing position no. 5, the bearing of the planet carrier at generator side. The bearing shows no irregularities.



Picture 6

Picture 6 shows bearing position no. 6, the bearing of the low speed shaft at rotor side. The bearing shows no irregularities.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 7 of 17	



Picture 7


Picture 7 shows bearing position no. 7, the bearing of the low speed shaft at generator side. The bearing shows no irregularities.



Picture 8


Picture 8 shows bearing position no. 8, the bearing of the intermediate shaft at rotor side. The bearing shows no irregularities.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 8 of 17	



Picture 9

Picture 9 shows bearing position no. 9, the bearing of the intermediate shaft at generator side. The bearing shows no irregularities.



Picture 10


Picture 10 shows bearing position no. 10, the bearing of the high speed shaft at rotor side. Small indentation visible at the rolling element.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015		Page 9 of 17



Picture 11


Picture 11 shows bearing position no. 11, the bearing of the high speed shaft at generator side. Several indentations visible at the raceway.



Picture 12


Picture 12 shows bearing position no. 11 again, the bearing of the high speed shaft at generator side. The bearing shows an area on the raceway where the surface is roughened.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 10 of 17	



Picture 13


Picture 13 shows the active flank of the ring gear. No irregularities.



Picture 14


Picture 14 shows one of the planet wheels. None of the planet wheels show irregularities.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 11 of 17	



Picture 15


Picture 15 shows the active flanks of the sun pinion. No irregularities.



Picture 16


Picture 16 shows the active flanks of the wheel of the low speed shaft in the linear stage. No irregularities.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 12 of 17	



Picture 17

Picture 17 shows the active flanks of the pinion of the intermediate shaft in the linear stage. No irregularities.



Picture 18

Picture 18 shows the active flanks of the wheel of the intermediate shaft in the linear stage. No irregularities.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 13 of 17	



Picture 19

Picture 19 shows the active flanks of the pinion of the high speed shaft in the linear stage. No irregularities.



Picture 20

Picture 20 shows the oil level of the gearbox.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 14 of 17	



Picture 21

Picture 21 shows the oil dip stick of the gear box. The dip stick is dry.



Picture 22

The inside and bottom of the gearbox have been searched with a magnet. The magnet shows no steel particles.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 15 of 17	

Datum:	Monteurs:	Werkzaamheden:
26-11-14	JBe, Dm	Schilderen
16-12-14	DJA/RP	Modificatie gelijkschieten in extra uitgerooid
24-12-14	JBe + Dm	Werkzaamheden aan de
13-1-15	Bik/BM/Ten	Werkzaamheden aan de
18-1-15	WJA / Bvd	Werkzaamheden aan de
25-3-15	Ten	Insp. Hoofdschakelaar + Tule
26-3-15	Aul + MH	Diagnose gear oil filter
10-5-2015	AVE / Ap	Play glas / ook Hoofdschakelaar getankt
2-5-15	Aux Ap	1/2 gear oil onderband + respunten
11-5-15	Aux Ap	6 pccy pccy's vervangen bl...
17-7-15	JJ + WJA	tekn filter WPC...
1-10-15	gds / WJA	

Picture 23

The logbook shows that the gear oil filter has been replaced quite often in the last year.

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015	Page 16 of 17	

5. Summary

The surface of the inner guide ring of the bearing of the first planet wheel is roughened.

The bearing of the high speed shaft at rotor side shows small indentation at the rolling element.

The bearing of the high speed shaft at generator side shows several indentations and a roughened surface at the raceway.

No irregularities were found at the other inspected bearings and gears.

The oil dip stick of the gearbox is dry.

No steel particles were found in the gearbox.

The logbook shows that the gear oil filter has been replaced quite often in the last year.

6. Conclusion

The condition of the gearbox is good enough to keep the gearbox in operation.

The irregularities at the planet bearing and the high speed bearings are remarkable and it is recommended to keep monitoring these bearings closely in the future.


The gear oil filter has been replaced quite often this year, which is probably caused by sludge in the gearbox.

The oil level is correct according to the glass, but the dip stick is dry. It is recommended to fill up the gearbox.

Dennis Lagerweij

Barneveld, 24-11-2015

TeSuCon B.V.
Mercuriusweg 8
3771NC Barneveld
The Netherlands
Tel +31610032858
Email dl@tesucon.nl
Web www.tesucon.nl

 TeSuCon Technical Support & Consultancy	Gearbox inspection Windpark Slufter West 2		15401268
	Date: 24-11-2015		Page 17 of 17