

Sound level report Energy Ball V200

The sound pressure level of the Energy Ball V200 was measured by Lichtveld Buis & Partners BV company, commissioned by Home Energy. The results show that, as expected, the sound pressure level of the Energy Ball is extremely low.

Measurements were performed at different standardized wind speeds. Only at wind speeds higher than 9 m/s the sound level turned of the Energy Ball V200 turned out to be higher than the background sound level generated by the wind.

Standardized wind speeds	Background sound pressure	Sound pressure level Energy
[m/s]	levels	Ball V200 at 50 m distance
	L n,k [dB(A)]	[dB(A)]
5	42.1	37
6	42.7	39
7	43.5	42
8	44.4	44
9	45.4	47

The next page shows a summary of the official sound report.

LBP Lichtveld Buis & Partners

Report summary

Nieuwegein, November 5th 2009 Number : V068304aaA0.md

Project : Sound emission V200

Location: Biervliet

This is a summary of report R068304aaA0.md d.d. November 5th 2009. Measurements were made according to 'Wind turbine generator systems – part 11' IEC61400-11, December 2002.

Turbine: Wind Energy Ball V200

Rotor diameter: 1.98 m

Hub height: 14 m (tube mast)

Rated power: 2250 W

Date of measurement: October 16th 2009

Location: Braakmanweg 1, Biervliet, the Netherlands

Sound pressure level at 50 m distance (with no reflecting or attenuating objects)

Wind class	Sound pressure level at 50 m [dB(A)]
Wind 5 m/s	37
Wind 6 m/s	39
Wind 7 m/s	42
Wind 8 m/s	44
Wind 9 m/s	47
Wind 10 m/s	50

Lichtveld Buis & Partners BV

ir. M.T. Dijkstra